



Republic of the Philippines

**ANGELES CITY WATER DISTRICT**

Pampang Road, Brgy. Lourdes Northwest, Angeles City  
(045) 458-0384; (045) 458-0382; (045) 458-0372  
(045) 322-6422; (045) 458-0371, Fax No.: (045) 322-6926

E-mail address: [angelescitywd@gmail.com](mailto:angelescitywd@gmail.com)  
Website: <http://www.angelescitywd.gov.ph/>

Date Prepared: January 7, 2020  
Date Approved: January 7, 2020  
Effectivity Date: January 7, 2020  
Control No.: BAC-01-06-20-001

Revision: 01

Revision Date: 02/16/19

Page 1 of 1

**SUPPLEMENTAL/BID BULLETIN  
ADDENDUM NO. 01**

**Title of Project:** SUPPLY AND DELIVERY OF 150 DRUMS GRANULAR CALCIUM HYPOCHLORITE FOR ANGELES CITY WATER DISTRICT

This Addendum No. 01 is issued to modify, amend and add items in the Bid Documents. This shall form an integral part of the Bidding Documents:

- TECHNICAL SPECIFICATION:

FROM:

ITEM
(A) Granular calcium hypochlorite should guarantee a yield of 67% available chlorine
(B) Must provide Certificate of Analysis for every lot delivered

TO:

ITEM
(A) Granular calcium hypochlorite should guarantee a yield of 67-70% available chlorine
(B) Must provide Certificate of Analysis for every lot delivered, which must include the parameters stated in items (a) to (e)

For guidance and information of all concerned.

**(Sgd) TRACY T. SALUNGA**  
BAC Chairperson

Received by the Bidder

Name: \_\_\_\_\_

Date: \_\_\_\_\_